

Section 13: Installation of Meters

Meters and remote readers will be furnished and placed by the District and are not to be disconnected or tampered with by the consumer. All meters shall be so located that they are not subject to freezing, protected from obstructions and permit ready access thereto for inspection and servicing, such location to be designated or approved by the District. Remote readers shall be located on the outside of buildings and be readily accessible to District personnel. All piping within the building must be supplied by the owner. Where additional meters are desired by the owner, the owner shall pay for all piping and an additional amount sufficient to cover the cost of maintenance and depreciation at the applicable rate set forth in the current rate schedule approved by the Public Service Commission and on file with the District. The owner shall install or cause to be installed 22 gauge three stranded wire encased in one-half inch (1/2") conduit from the meter to the exterior front or side of the building.

adopted 10/20/2010